

ADDENDUM 2

DATE: Dec. 16, 2014

PROJECT: Rome Floyd Law Enforcement Center Chiller Replacement

PROJECT NUMBER: 705-1402

OWNER: Floyd County Georgia

ENGINEER: Drinkard Engineering Group, Inc.

TO: All Bidders

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents, with amendments and additions noted below.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.

CHANGES TO PLANS AND/OR SPECIFICATIONS

None.

CLARIFICATIONS/RESPONSES TO QUESTIONS

1. A clarification to Specification Change #4 from Addendum 1:

The contractor will NOT be required to import or organize data from the 4 existing locations listed in Addendum 1 as part of the scope of work for the Rome-Floyd County Law Enforcement Chiller Replacement. However a central server will be installed and serve as the supervisory system for this project, the graphical user interface, alarm and historical database location will be developed on and accessible from the central server. Additional sites will be migrated into the new BAS Central Server as part of a separate agreement with Floyd County in the future.

2. Modify answer to question #6 from Addendum 1 to allow other brands of space sensors, as long as they have the same form and function as the Honeywell Zio TR71. Space sensors that do not have the same form and function will now be allowed.

END OF DOCUMENT