

NOTICE TO LETTING
TO EXISTING PLAN HOLDERS
INVITATION TO BID
FULTON ROAD MEMBRANE FILTRATION FACILITY
FOR THE
FLOYD COUNTY BOARD OF COMMISSIONERS

Notice is hereby given that Floyd County, Georgia (Owner), proposes to let a Contract to the lowest responsible, responsive bidder, upon sealed bids for Construction of the Fulton Road Membrane Filtration Facility.

Sealed bids will be received until 2:00 PM (local time), on Thursday, June 5, 2014, at the office of the Floyd County Purchasing Director, located in the Floyd County Administration Building, 12 East Fourth Avenue, Suite 106, Rome, Georgia. Sealed bids will then and there be publicly opened and read aloud in the office of the Purchasing Director. Late bids will not be accepted.

All addendums, contract documents, specifications and plans previously issued remain in force. In addition, prospective bidders shall make note of the following modification of the original Bidding Documents.

- Item 1 Page 00 4585-1, DELETE the paragraph beginning with the words, "That this bid" and SUBSTITUTE the following paragraph:
That this bid may be withdrawn by requesting such withdrawal in writing at any time prior to Thursday, June 5, 2014 at 2:00 P.M. EDST but may not be withdrawn after such date and time.
- Item 2 Page 00 7200-6, ADD the following paragraph:
15.4.4 To any delays due to late delivery of major project equipment when said equipment was ordered in a timely manner by the CONTRACTOR.
- Item 3 Page 40 9000-10, Paragraph 3.2 E.: DELETE the sentence beginning with "Upon completion of installation" and SUBSTITUTE the following:
Upon completion of installation, services of the above service engineer shall be provided for a period of not less than two 8-hour days for calibration and start-up of equipment and instruction of operating personnel.
- Item 4 Page 40 9050-14, Paragraph 2.4.A. DELETE the words "*Two (2) one-day graphic display design meetings*" and SUBSTITUTE the words "*One (1) one-day graphic display design meeting*"
- Item 5 Page 40 9050-14, Paragraph 2.5.A. DELETE the words "*Three (3) one-day process control strategy design meetings*" and SUBSTITUTE the words "*One (1) one-day process control strategy design meeting*"
- Item 6 Drawing No. E-4, CHANGE VFDs for the two high service pumps in MCC1 from 75HP to 100HP.
- Item 7 Drawing No. E-7, Hex Note 8, in the first sentence DELETE 75 HP and ADD 100 HP.
- Item 8 Drawing No. E-7, Hex Note 8, DELETE the sentence
"PROVIDE 1 1/2"C, 3#1, #1 GND, 4#14 FOR POWER,"
and ADD the following:
"PROVIDE 2"C, 3#2/0, #1 GND, 4#14 FOR POWER,"

May 28, 2014
(Date)

Floyd County Purchasing
/s/ Nancy Lam, Purchasing Director