



PURCHASING DEPARTMENT

TWELVE EAST 4TH AVENUE, SUITE 106 • POST OFFICE BOX 946 • ROME, GEORGIA 30162
PHONE: 706.291.5118 • FAX: 706.290.6099 • www.romefloyd.com

ADDENDUM # 1

TO: ALL PROSPECTIVE BIDDERS

Date: 5/3/12

Subj: Floyd County Georgia invitation to bid; 12-0517 DUCTILE PIPE

Question: What Class of Ductile Pipe is required?

Answer: Class 50

This addendum is to be acknowledged and returned with your bid package.

Name of Company _____

Signature _____

Thank you,
Everett Gray CPPB

BOARD OF COMMISSIONERS
IRWIN BAGWELL, CHAIRMAN
GARRY FRICKS, VICE-CHAIRMAN
JOHN MAYS

ADMINISTRATION
NANCY LAM, CPPB, CPPO, PURCHASING DIRECTOR
EVERETT GRAY, CPPB, PURCHASING AGENT