



**Bid #032-15 Addendum #3**  
**Questions/Answers**

1. Since there is a cost difference when figuring the GPM for the Rome Landfill pumping unit, what GPM would be sufficient? Would you want to figure for a 22 GPM or a 50 GPM?

Answer: The 22 GPM will be sufficient.