



PURCHASING DEPARTMENT

TWELVE EAST 4TH AVENUE, SUITE 106 • POST OFFICE BOX 946 • ROME, GEORGIA 30162
PHONE: 706.291.5118 • FAX: 706.290.6099 • www.floydcountyga.org

ADDENDUM # 2

To: The Mandatory Pre-Bid list of Contractors

Date: 21 September 2015

Subj: **Floyd County Georgia Bid 15-1001 Roof Replacement Forum Civic Center**

Question: Will Floyd County accept other manufactures products other than Dura-Last?

Answer: Yes, provided the product meets or exceeds the minimum specifications as written

Question: What will the amount for liquidated damages be on this project?

Answer: This was previously answered in addendum 1. Liquidated damages for this project will be \$500 per day.

Question: Spec Section 1.4, Sub Section C- Shop Drawings Calls for indication of insulation patters. Is this required for this project?

Answer: There are no insulation pattern drawing requirements for this project. SPECIFICATION CHANGE

Question: Spec Section 3.3, Sub Section C- Specifies the use of water based adhesive. Will the county allow low VOC type adhesive?

Answer: Yes the County will allow low VOC type adhesive. SPECIFICATION CHANGE

Question: How will damage to deck be addressed during the project?

Answer: Deck repair will be brought to Counties attention and after a visual inspection by the county, the repairs will be made at the rate per square foot. Price will include all materials and labor.

Replace the original bid form the revised bid form attached which includes the per square foot price for deck repair.

BOARD OF COMMISSIONERS
LARRY MAXEY, CHAIRMAN
GARRY FRICKS, VICE-CHAIRMAN
IRWIN BAGWELL
RHONDA S. WALLACE
SCOTTY HANCOCK

ADMINISTRATION
NANCY LAM, CPPB, CPPO, PURCHASING DIRECTOR
EVERETT GRAY, CPPB, PURCHASING AGENT

Floyd County Georgia Bid 15-1001 Roof Replacement Forum Civic Center

Question: What will be the process if the existing light weight deck is wet?

Answer: The contractor will be responsible for drying the deck should wet conditions be found.

Repairs to Lightweight Concrete

Floyd County will accept any product comparable to USG SECUROCK Brand Gypsum-Concrete Patch with a 500 PSI Compressive Strength, Non Combustible and can be applied to dry lightweight concrete surfaces. Awarded contractor will provide the exact product information to the Facilities Director for Pre-Approval. Contractor must apply the patch in accordance with manufactures specifications.

NEW INFORMATION

Floyd County is providing engineering drawings in PDF format pertaining to the underlying structure of the Forum roof should the awarded contractor need them. These are labeled "Forum Plans 0001", 0002, 0003, and 0004. The Drawings are located on the Floyd County Website

You are acknowledging this addendum is understood and to be returned with your bid package. This Addendum becomes part of the bid specifications.

Name of Company _____

Signature _____

Date _____

Thank you, Everett Gray CPPB