



# PURCHASING DEPARTMENT

TWELVE EAST 4<sup>TH</sup> AVENUE, SUITE 106 • ROME, GEORGIA 30161

PHONE: 706.291.5118 • FAX: 706.290.6099 • [www.romefloyd.com](http://www.romefloyd.com)

Date: 10 May 2016

To: To Whom It May Concern

## **Request for Quote: 16-0526 Rockdale Pump Station**

Floyd County is requesting quotes for the removal and installation of pumps at Rockdale Pump Station for the Floyd County Water Department. Details are outlined in the scope of work within this document.

All quotes will be submitted on the attached quote sheet. Additional information may be submitted with quote. Quotes are to include all labor equipment including and shipping and delivery. Quotes submitted will be FOB Destination (Rome Ga. 30161).

Submissions must include a completed E-Verify Form (Contract Affidavit and Agreement). This form is provided in this RFQ. Companies that do not provide this will not be considered.

Quotes are due no later than 2pm 26 May 2016. Quotes may be submitted by Email, Fax, US Mail or hand delivered to this office. Fax 706 290-6099 – Email: [Graye@floydcountyga.org](mailto:Graye@floydcountyga.org)

Quotes are to remain valid for a period of 30 days from the date of quote. Awards may be for all or part of what is submitted

Questions regarding this RFQ will be faxed 706 290-6099 or Email: [Graye@floydcountyga.org](mailto:Graye@floydcountyga.org)  
Questions will be taken until Friday 20 May 2016

Typically award notification will be by email. Tabulations will be posted to the Floyd County Website and the Georgia Procurement Registry in approximately 24hrs after the due date/time.

### **Payment Options, Invoicing, and Terms and Conditions**

**If payment is made by check, Floyd County will pay invoice(s) within 30 days of receipt of a valid invoice. Supplier may be required to send a current W-9 prior to have a Purchase Order issued. The Issued Purchase Order will serve to initiate the order when payment is going to be made by check. If payment is made by credit card this information will be provided at the time of order, however, the successful suppliers must agree that no charge will be run until such time as the products have shipped or the service has been provided. A paid receipt or paid invoice will be provided to the card bearer. Floyd County is Tax Exempt.**

#### **BOARD OF COMMISSIONERS**

LARRY MAXEY, CHAIRMAN  
RHONDA S. WALLACE, VICE-CHAIRMAN  
IRWIN BAGWELL  
GARRY FRICKS  
SCOTTY HANCOCK

#### **ADMINISTRATION**

NANCY LAM, CPPB, CPPO, PURCHASING DIRECTOR  
EVERETT GRAY, CPPB, PURCHASING AGENT

**Floyd County Georgia**  
**RFQ 16-0526**  
**Rockdale Pump Station**

**Scope of Work & Specifications**

The work covered by this section of the specifications consists of contractor furnishing all labor, supplies, equipment, and materials. **All work and material shall meet the Georgia “Minimum Standards for Public Water Systems”.**

**CONTRACTOR WILL:**

- Eliminate/minimize interruptions in water service to customers by performing the work as described below and pictures attached.
- Turn over all removed equipment to Floyd County

**MATERIAL RESTRICTIONS:**

All material that comes in contact with drinking water, including pipe, fittings, and other appurtenances must be NSF Standard 61 certified. Any pipe, solder or flux used in the installation shall be lead free with not more than 8.0% lead in pipes and fittings, and not more than 0.2% lead in solders and flux.

**LOCATION:** Rockdale Pump Station, located at 4 Rockdale Rd. Silver Creek Ga. 30173.

**Remove** existing manual starters (2) along with the existing disconnect switches

**Install**

2 - Franklin 3 h.p. 9VR-3 Stainless Steel Vertical Multi-Stage Pump and motor (single-phase), or equal.

1 – 119 gallon pressure tank (150 psi max)

Two new combination starters

The combinations starters will each consist of a fused disconnect switch, a motor starter, and an on-off switch (120-volt controls).

After a power outage, each of the starters will go back to the state they were in before the interruption (e.g. if in the run position the starter will come back on with the power).

All starters, disconnects, breakers, and switches shall be Square D, General Electric, or Cutler Hammer. All electrical construction shall be in accordance with the National Electrical Code, 2005 Edition, OSHA, the Georgia State Electrical Code and all local requirements.

**ACCEPTANCE:** Floyd County Water Department will perform the acceptance inspection with contractor and once approved the contractor will submit invoice for payment.

**SITE VISITS:** Contact Troy Atkins at 706 291-5172 or [atkinst@floydcountyga.org](mailto:atkinst@floydcountyga.org)

**Comparable Equipment:** Contractor may submit for consideration equipment of comparable design, quality and capacity.

**Floyd County Georgia  
RFQ 16-0526  
Rockdale Pump Station  
Quote Due not later than 2pm on 26 May 2016**

**QUOTE PAGE**

**We the undersigned have been given the opportunity to visit and inspect the place of work, agree to perform the services in accordance with the specifications, scope of work, terms and conditions issued for the same at the following pricing.**

\$ \_\_\_\_\_

**Pump Manufacturer & Model** \_\_\_\_\_

**Tank Manufacturer & Model** \_\_\_\_\_

**Days to start project from award** \_\_\_\_\_ **Calendar Days**

**Days to complete** \_\_\_\_\_ **Calendar Days**

**Contractor Information**

Contact Person: \_\_\_\_\_ (Print or Type Name)

Telephone Number(s):    P \_\_\_\_\_    F \_\_\_\_\_    C \_\_\_\_\_

Email Address \_\_\_\_\_

Company Name \_\_\_\_\_

Billing Address \_\_\_\_\_

Signature \_\_\_\_\_ Date \_\_\_\_\_

**Specify Preferred Payment Method**

\_\_\_\_\_ **Check** - Paid within 30 days of invoice - Supplier is requested to provide current W-9

\_\_\_\_\_ **Credit Card** – Will be provided at shipment with no transaction fee)

**Contractor Affidavit under O.C.G.A. § 13-10-91(b)(1)**

By executing this affidavit, the undersigned contractor verifies its compliance with O.C.G.A. § 13-10-91, stating affirmatively that the individual, firm or corporation which is engaged in the physical performance of services on behalf of Floyd County Georgia has registered with, is authorized to use and uses the federal work authorization program commonly known as E-Verify, or any subsequent replacement program, in accordance with the applicable provisions and deadlines established in O.C.G.A. § 13-10-91. Furthermore, the undersigned contractor will continue to use the federal work authorization program throughout the contract period and the undersigned contractor will contract for the physical performance of services in satisfaction of such contract only with subcontractors who present an affidavit to the contractor with the information required by O.C.G.A. § 13-10-91(b). Contractor hereby attests that its federal work authorization user identification number and date of authorization are as follows:

\_\_\_\_\_  
Federal Work Authorization User Identification Number

\_\_\_\_\_  
Date of Authorization

\_\_\_\_\_  
Name of Contractor

\_\_\_\_\_  
Address of Contractor

RFQ 16-0526 Rockdale Pump Station

\_\_\_\_\_  
Name of Project

FLOYD COUNTY GEORGIA

\_\_\_\_\_  
Name of Public Employer

I hereby declare under penalty of perjury that the foregoing is true and correct.

Executed on \_\_\_\_\_, \_\_\_\_ in 201\_\_ in \_\_\_\_\_(city), \_\_\_\_\_(state).

\_\_\_\_\_  
Signature of Authorized Officer or Agent

\_\_\_\_\_  
Printed Name and Title of Authorized Officer or Agent

SUBSCRIBED AND SWORN BEFORE ME

ON THIS THE \_\_\_\_\_ DAY OF \_\_\_\_\_, 201\_\_.

\_\_\_\_\_  
NOTARY PUBLIC

My Commission Expires: \_\_\_\_\_ (Notary Seal or Stamp Required)



