



Sammy H. Rich, *City Manager*
DEPARTMENT OF PUBLIC SERVICES
W. Kirk Milam, P.E., *Manager*
Engineering Services Department
Aaron Carroll, R.L.S., P.E., *Director*

**WALKER MOUNTIAN MSWLF
PUMP STATION
(Bid No. 046-15)**

ADDENDUM NO. 1
October 7, 2015

Contract Documents and Detail Specifications

Replace 2.04 (c) (1) with the following:

Pipe: All Polyethylene pipe shall be manufactured in accordance with AWWA C901-2 for sizes 1-1/4" thru 3" IPS diameters and to the requirements of ASTM D3035. Pipe 4" and above DIPS and IPS sized shall be manufactured to the requirements of ASTM F714 and AWWA C906-07. Pipe for this project shall be DriscoPlex 4000 IPS Green Stripe or EQUAL.

Replace 2.04 (c) (3) with the following:

Service Identification Stripes: Permanent identification of the piping service shall be provided by co-extruding color stripes into the pipe outside surface. The striping material shall be the same material as the pipe material except for color. Stripes printed on the outside surface shall not be acceptable. Pipe shall have six equally spaced, longitudinal color stripes. The stripes for this project shall be green

This Addendum is being issued as a result of questions submitted to owner and additional review of documents.
The Bid must acknowledge the receipt of this Addendum

200 Vaughn Road • PO Box 1433 • Rome, Georgia 30162-1433
phone: 706/378-3846 • fax: 706/236-4532

www.rome.ga.us