



# PURCHASING DEPARTMENT

TWELVE EAST 4<sup>TH</sup> AVENUE, SUITE 106 • POST OFFICE BOX 946 • ROME, GEORGIA 30162  
PHONE: 706.291.5118 • FAX: 706.290.6099 • www.floydcountyga.org

## ADDENDUM # 2

To: Interested Companies

Date: 14 March 2016

Subj: **Floyd County Georgia Request for Quote 16-0315 LED Fixtures and Bulbs**

**Due to questions regarding this RFQ, Floyd County is extending the submission deadline to 2pm March 18, 2016.**

**QUESTION 1:** Can you please double check the information on these items. Can you double check the mfg numbers, Lithonia is telling us the , the part numbers provided for quotation are missing nomenclature or are incomplete.

LITHONIA LIGHTING 2VTL4R40LLP835 4X2 RETRO P000003BV

LITHONIA LIGHTING 2VTL2RT20LLP835 2X2 RETRO P000003CE

**ANSWER:** Models are corrected to the following:

2VTL4R 40L ADP EZ1 LP835 for the 4x2 fixtures and 2VTL2R 20L ADP EZ1 LP835 for the 2x2 fixtures

**QUESTION 2:** Need to know the following for the threaded rod retrofit kit:

8 Global Tech LED GTR Threaded Rod Retrofit Kit GTSOL5498x3, NO SUBSTITUTION SR16-2R1

10 Global Tech LED GTR-HB-5498-HO-SV-GR-NLSOLY Mogul Base Retrofit Kit, SR15-12R1 NO SUBSTITUTION

1. Wattage (Cut sheet has 405 watts)
2. Voltage
3. Threaded rod length (choices are 16.5" and 19.5")

**ANSWER:**

1. Wattage is 405 watts
2. Voltage is 277 Volts
3. Threaded rod length is 19.5"

***You are acknowledging this addendum is understood and to be returned with your bid package. This Addendum becomes part of the bid specifications and requirements.***

Name of Company \_\_\_\_\_

Signature \_\_\_\_\_ DATE \_\_\_\_\_

BOARD OF COMMISSIONERS  
LARRY MAXEY, CHAIRMAN  
GARRY FRICKS, VICE-CHAIRMAN  
IRWIN BAGWELL  
RHONDA S. WALLACE  
SCOTTY HANCOCK

ADMINISTRATION  
NANCY LAM, CPPB, CPPO, PURCHASING DIRECTOR  
EVERETT GRAY, CPPB, PURCHASING AGENT