

ADDENDUM #1

DATE: Sept. 7, 2016

PROJECT: Floyd Co. Judicial Center Cooling Tower Replacement

OWNER: Floyd County, GA

ENGINEER: Drinkard Engineering Group, Inc.

TO: All Bidders

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents, with amendments and additions noted below.

Acknowledge receipt of this Addendum on the Bid Form. Failure to do so may disqualify the Bidder.

CHANGES TO BID PACKET

1. Modify Section 15640 – Sections 2.1 and 2.2 specifying Evertough/Tri-armor basin as basis of design shall be nullified. Only 304 welded stainless steel basin will be allowed on this project – no alternates.

END OF DOCUMENT