

Visitability Requirements for CHIPBuild 2018 OCGA 8-3-172:

1. One “No Step Entry” through 36 inch door
2. On first floor:
  - a. Each interior door is at least a standard 32 inch door, unless the door provides access only to a close of less than 15 square feet in area;
  - b. Each hallway has a width of a least 36 inches and is level, with ramped or beveled changes at each door threshold;
  - c. Each bathroom wall is reinforced for potential installation of grab bars;
  - d. Each electrical panel or breaker box (located inside on first floor), light switch, or thermostat is not higher than 48 inches above the floor; and
  - e. Each electrical plug or other receptacle is at least 15 inches above the floor.