



Public Works Department

337 BLACKS BLUFF RD • ROME, GEORGIA 30161
PHONE: 706.236.2495 • FAX: 706.291.2487 • www.romefloyd.com

ADDENDUM # 1

To: To Whom It May Concern

Date: 2/14/19

Subj: **ADDENDUM 1: BID 19-0221-1 Drainage Pipe**

Floyd County makes the following clarification of the Bid Specifications and Requirements

Question

Bituminous coated galvanized steel pipe is being discontinued this year by the remaining suppliers, ourselves and Contech. Would you accept a bid for aluminized type 2 corrugated steel pipe instead?

GDOT uses aluminized CMP (aluminum coated type 2) for storm drain pipe and now longer allows bituminous coated pipe (see attached document).

Answer

Floyd County will accept aluminized type 2 corrugated steel pipe. Bidders are to identify this type of pipe on the Bid Page.

You are acknowledging this addendum is understood and to be returned with your bid package. This Addendum becomes part of the bid requirements.

Name of Company _____

Signature _____ DATE _____

BOARD OF COMMISSIONERS
RHONDA S. WALLACE, CHAIRMAN
SCOTTY HANCOCK, VICE-CHAIRMAN
WRIGHT BAGBY
LARRY MAXEY
ALLISON WATTERS

PUBLIC WORKS
MICHAEL SKEEN, *DIRECTOR* 706.236-2476
JAYNE DIGGS, ADMINISTRATIVE ASSISTANT, 707.236.2495
EVERETT GRAY, WAREHOUSE MANAGER, 706.236-2489
BRAD WALKER, FLEET MAINTENANCE, 706.236.2482
ERIC SEXTON, BRIDGE AND RIGHT OF WAY 706.236-2477
WAYNE ALLEN, PAVING AND ROADS, 706.236.2478
BRUCE IVEY, COUNTY ENGINEER, 706.236-2474