

Rome Tennis Center at Berry College
Request for Qualifications & Proposals (RFP #011-19)
Construction & Materials Testing Services



Addendum No. 1

QUESTIONS & ANSWERS

Q1. Will the pre-engineered metal building manufacturer's submittals include a schedule of special inspections specific to the PEMB?

A1. Specification Section 01 45 25 lists the Special Inspections needed for steel to meet code requirements. No additional inspections specific to the PEMB manufacturer are anticipated.

Q2. The RFP says to "limit your submittal to forty (40) single-sided pages or twenty (20) double-sided pages." Please advise if the following will be included in the page count:

- Certificate of Insurance
- Documentation that our firm is an "Approved Testing Agency" meeting requirements of IBC Section 1703 and ASTM E-329
- Resumes
- Cost Proposal Form
- Draft Owner-Consultant Agreement
- Supporting Documents (i.e., the Bidder's Declaration, Certificate of Non-Discrimination, Non-Collusion Affidavit, Drug Free Work-Place Certification, E-Verify Affidavit, SAVE Affidavit, Tax Identification and Certification (W-9), and State of Georgia Prompt Pay Act Affidavit)

A2. All requested documents, except the Draft Owner-Consultant Agreement, are to be included in the 40-page count. Please include your Draft Agreement as an Appendix to the proposal.