



PURCHASING DEPARTMENT

12 EAST 4TH AVENUE, SUITE 106 • ROME, GEORGIA 30161
PHONE: 706.291.5118 • www.romefloyd.com

Addendum II Questions and Answers

The Anthony Center Roof Replacement Bid #20-0407

Question: What are flute fill material (EPS, ISO?) and filler profile (taper cut, square cut, profile cut?).

Answer: ISO is preferred and the profile should be "square cut"

Question: At the pre-bid site tour, it was stated that under normal conditions, it would be regular Monday-Friday daytime work hours, will this generally be the same hours?

Answer: Daylight to dark, Seven days a week.

Question: Page 3 of the ITB states "All bonds must be signed or countersigned by a Georgia Resident Agent", can you clarify countersigned by a Georgia Resident Agent?

Answer: The Agent must be licensed agent to do business in Georgia.

Question: Windlift mph requirement for warranty?

Answer: 55 MPH is the minimum.

Change #2, Bidders should include the cost of replacing the gutters and downspouts at the back of the building. They should be of a similar quality and style as the existing gutter and downspouts.

Thanks,
Bill Gilliland
Purchasing Director
Floyd County Board of Commissioners

BOARD OF COMMISSIONERS

SCOTTY HANCOCK, CHAIR
WRIGHT BAGBY, VICE-CHAIR
RHONDA WALLACE
ALLISON WATTERS
LARRY MAXEY

ADMINISTRATION

JAMIE McCORD, COUNTY MANAGER
GARY BURKHALTER, ASSISTANT COUNTY MANAGER
BILL GILLILAND, DIRECTOR
RANDY SELF, ASSISTANT DIRECTOR