



**PURCHASING DEPARTMENT**

Becky Smyth, Director  
Jackson Abercrombie, Purchasing Agent  
Gina Brown, Buyer  
Kaitlin Newport, Buyer

**ADDENDUM II**  
**QUESTIONS AND ANSWERS**

**\*\*The bid opening will be postponed until Thursday, June 18, 2020 at 10:00 a.m.\*\***

1. The contract drawings call for aluminum platform on drawing PS-1A, and then calls for galvanized platform on PS-S1, and S2. There is much more detail shown for the galvanized materials. Should we assume galvanized?

**Yes, galvanized should be utilized per the structural drawings, the callout on PS-1A is a typo, and will be revised on the construction set.**

2. For the 2" Gasline, where should the contractor assume the meter will be placed by Atlanta Gaslight? In other words, will the gas line be installed from the road to the fence of the pump station by AGL or will the contractor be responsible for the gas line from the ROW to the station?

**The meter should be assumed to be placed at the ROW line. Assume that the line will have to be installed by the contractor from the ROW line to the station.**

Thank you,

Becky Smyth  
Purchasing Director

601 Broad Street • PO Box 1433 • Rome, Georgia 30162-1433  
*phone: 706/236-4410 • fax: 706/236-4549*

[www.romea.us](http://www.romea.us)